



March 25, 2013

Ms. Marcia Gasses
Town Planner & Land Use Administrator
Town of Barrington
PO Box 660
Barrington NH 03825

SUBJECT: Yellow Dog's Barn – Map 270 Lot 71
Engineering Review Services

Dear Ms. Gasses:

As requested, we have completed our second review of the proposed site plan application for the above referenced project. Our review services were limited to a review of the stormwater report by Jones & Beach Engineers (dated January 16, 2013 with no revision date) and associated Site Plan (dated January 16, 2013 with a revision date of February 27, 2013). The following were comments noted during the review:

1. We recommend that the drainage report cover sheet includes a revision date.
2. We recommend that the Infiltration Trench Detail Note No. 2 (located on Drawing D1) be modified to state that if the infiltration rate results yield less than the 0.4 inches per hour (as identified within the drainage report) the infiltration trench design shall be updated and re-submitted to the Town for review.

If you should have any questions or comments, please call me.

Very truly yours,
DuBOIS & KING, Inc.

Jeffrey A. Adler, P.E.
Sr. Project Manager

SMB/js